

Elevate PVC Roof Systems

Tested Assembly Guide

Canadian Standards Association

May 2024

NOTE: The contents of this guide are considered accurate at time of posting. All information contained within should be validated for accuracy as it relates to specific project conditions or requirement. Specific codes, uplifts or other factors may result in changes to the information contained within this document. Validate all specific conditions with a Holcim Regional Technical Coordinator prior to its use.

5/13/2024 Elevate PVC Roof Systems Tested Assembly Guide – Canadian Standards Association

Table of Contents

Canadian Standards Association	
Allowable Products	3
Optional Components	3
Safety Factor	3
Admissible Wind Uplift Load Calculation	3
Technical Advisories	3
Values	
Notice	3
Decking	3
PVC Single-Ply Adhered Membrane	3
PVC Single-Ply Attached Membrane	5
PVC Single-Ply Plate Bonded Membrane	5

Canadian Standards Association

Allowable Products

Only equivalent products included into the roofing system's report are admissible.

Optional Components

Components of the roofing system designated as optional may be included or excluded from the roofing system which will not change the published dynamic uplift resistance (DUR).

Safety Factor

As required by the CSA A123.21 Standard, the published dynamic uplift resistance (DUR) are reduced by a safety factor of 1.5 (SF of 1.5).

Admissible Wind Uplift Load Calculation

An online calculator is available at www.sigders.ca.

The user will have to provide the following information:

- Building Location
- Building Geometry
- Building Exposure
- Building Openings
- Building Importance Factor

The calculator will display the allowable design load of the roof's field surface, edges and corners as well as the dimensions of the edge and corner zones.

Technical Advisories

Assessment reports must be read in conjunction with technical advisories issues by Exp Services Inc.

Values

A For the listing in this section the metric values are the standard and values in parentheses are for information only.

Notice

Exp Services Inc. reserve their right to withdraw, without prior notice, the test report performed as per CSA A123.21 Standard.

Decking

Galvanized construction steel or coated with aluminum/zinc allow or PVC in accordance with ASTM A653, ASTM A792, ASTM A1008 or CSSBI 10M Standards. Supplier is listed as Generic. The deck's fastening to the supporting structure must be strong enough to resist the wind uplift loads (adjusted as per NBC requirements). Contact a Holcim Technical Representative for additional deck availability. Alternate deck types will require the deck to have a pullout resistance equal to or higher than the fastening uplift resistance specified in the given listing.

Deck used for testing: 22 gauge, Yield Strength (Y) 33 ksi, Tensile Strength (T) 45 ksi – Type B

PVC Single-Ply Adhered Membrane

PVC Single-Ply Membrane - Dynamic Uplift Resistance (DUR) as per CSA A123.21

Deck Type & Uplift with SF of 1.5	Vapor Barrier/ Thermal Barrier	Insulation and Attachment	Cover Board and Attachment	Membrane and Attachment
Steel	Vapor Barrier:	Insulation:	Cover Board (Optional):	Membrane:
22 ga	V-Force	50.8 mm	Min. 6.4 mm (1/4")	PVC or PVC KEE*
RD938	BaseGard SA	(2") thick,	Securock, DensDeck or	1.3 mm (50 mil)
230 MPa	Polyethylene	ISOGARD GL/ISOGARD CG,	DensDeck Prime	
(33.4 ksi)	Kraft paper	ISOGARD HG	-or-	Attachment:
		ISOGARD HD Composite	12.7 mm (1⁄2") thick	Full Coverage
2.693 kPa	Thermal Barrier (Optional):		ISOGARD HD	PVC Water Based Bonding
(-37.5 psf)	6 mm – 15.9 mm	Attachment:	-or-	Adhesive,
	(1⁄4" - 5⁄8") thick,	8 HD Fasteners	Min. 11.1 mm (7/16")	PVC LVOC Bonding
Project No:	DensDeck	per 1219 mm x 2438 mm	APA rated OSB	Adhesive

20-06- B0122-5	DensDeck Prime Securock	(4 ′ x8 ′) board	Attachment: 12 HD Fasteners/Plates	Note : Do not use PVC WBBA wit
	<i>Attachment:</i> <i>Loose Laid</i>		per 1219 mm x 2438 mm (4 ' x8 ') board	PVC KEE Membrane
Steel 22 ga RD938 230 MPa (33.4 ksi) 2.235 kPa	Vapor Barrier: V-Force BaseGard SA Polyethylene Kraft paper Thermal Barrier 6 mm – 15.9 mm (1⁄4" - 5⁄8") thick,	Insulation: 38.1 mm (1.5") thick, ISOGARD GL/ISOGARD CG, ISOGARD HD Composite -or- 50.8 mm 50.8 mm S0.8 mm (2") thick, ISOGARD HG	Cover Board: Min. 6.4 mm (¼") Securock, DensDeck or DensDeck Prime -or- 12.7 mm (½") thick ISOGARD HD -or- Min. 11.1 mm (7/16")	Membrane: PVC XR, PVC KEE XR 1.5 mm (60 mil) Attachment:
(-46.67 psf) Project No: 20-06- B0122-6	(74 - 78) thick, DensDeck DensDeck Prime Securock Attachment: Loose Laid Vapor Barrier:	Attachment: 8 HD Fasteners per 1219 mm x 2438 mm (4 ' x8 ') board	APA rated OSB Attachment: 12 HD Fasteners/Plates per 1219 mm x 2438 mm (4 ' x8 ') board	Full Coverage PVC Water Based Bondir Adhesive
Steel 22 ga RD938 230 MPa (33.4 ksi) 1.795 kPa (-37.5 psf) Project No: 20-06- B0122-4	V-Force BaseGard SA Polyethylene Kraft paper Thermal Barrier (Optional): 6 mm – 15.9 mm (¼" - 5%") thick, DensDeck DensDeck DensDeck Prime Securock Attachment:	Insulation: 50.8 mm (2") thick, ISOGARD GL/ISOGARD CG, ISOGARD HD Composite Attachment: 8 HD Fasteners per 1219 mm x 2438 mm (4' x 8') board	Cover Board: N/A Attachment: N/A	Membrane: PVC XR or PVC KEE XR 1.5 mm (60 mil) Attachment: ISO Spray R, Twin Jet or X Stick Membrane Adhesiv ribbon applied 305 mm (12 o.c.)
Steel 22 ga RD938 230 MPa (33.4 ksi) 3.59 kPa (-75 psf) Project No: 21-06-B0123-1	Loose Laid Vapor Barrier: V-Force BaseGard SA Polyethylene Kraft paper Thermal Barrier (Optional): 6 mm – 15.9 mm (¼" - 5%") thick, DensDeck DensDeck Prime Securock Attachment: Loose Laid or Tacked In Place	Insulation: 50.8 mm (2") thick, ISOGARD GL/ISOGARD CG Attachment: 8 HD Fasteners per 1219 mm x 2438 mm (4 ' x8 ') board	Cover Board: N/A Attachment: N/A Cover Board:	Membrane : PVC 1.3 mm (50 mil) Attachment : Full Coverage Jet Bond PVC Spray Adhesive
Steel 22 ga RD938 230 MPa (33.4 ksi) 1.795 kPa (-37.5 psf) Project No: 21-06-B0123-2	Vapor Barrier: V-Force BaseGard SA Polyethylene Kraft paperThermal Barrier (Optional): 6 mm – 15.9 mm (¼" - 5%") thick, DensDeck DensDeck DensDeck Prime SecurockAttachment: Loose Laid or Tacked In Place	Insulation: 50.8 mm (2") thick, ISOGARD GL/ISOGARD CG Attachment: 8 HD Fasteners per 1219 mm x 2438 mm (4 ' x8 ') board	Kover Board: Min. 6.4 mm (¼") Securock, DensDeck, DensDeck Prime or DensDeck StormX -or- 12.7 mm (½") thick ISOGARD HD -or- 1.5" (38.1 mm) ISOGARD HD COMP. ISOGARD HG -or- Min. 11.1 mm (7/16") APA rated OSB Attachment: 12" (304.8 mm) o.c. beads ISO Spray R, ISO Twin Pack or ISO Stick	Membrane : PVC 1.3 mm (50 mil) Attachment : Full Coverage PVC Water Based Bondir Adhesive

Elevate PVC Roof Systems Tested Assembly Guide – Canadian Standards Association

PVC Single-Ply Attached Membrane

PVC Single-Ply Membrane - Dynamic Uplift Resistance (DUR) as per CSA A123.21

Pvo ongle-Fly Membrane - Dynamic Opint nesistance (Don) as per OOA A120.21				
Deck Type & Uplift with SF of 1.5	Vapor Barrier/ Thermal Barrier	Insulation and Attachment	Cover Board and Attachment	Membrane and Attachment
Steel 22 ga Y : 40 ksi 2.544 kPa (-53 psf) Project No: 2b-FBP-21- LSWUD-01.A	Vapor Barrier: V-Force BaseGard SA Polyethylene Kraft paper Thermal Barrier (Optional): 6mm – 15.9 mm (1⁄4" - 5⁄8") thick DensDeck DensDeck DensDeck Prime Securock Attachment: Loose Laid	Insulation: Cover Board Used: Min. 1.5" ISOGARD GL/ISOGARD CG, ISOGARD HG, ISOGARD HD Composite No Cover Board: 50.8 mm (2") thick, ISOGARD GL/ISOGARD CG, ISOGARD HG ISOGARD HD Composite Attachment: 8 HD Fasteners and plates per 1219 mm x 2438 mm (4 ' x 8 ') board	Cover Board (Optional): Min. 6.4 mm (¼") Securock, DensDeck or DensDeck Prime -or- 12.7 mm (½") thick ISOGARD HD -or- Min. 11.1 mm (7/16") APA rated OSB Attachment: 8 HD Fasteners and plates per 1219 mm x 2438 mm (4' x8') board	Membrane: PVC or PVC KEE 1.3 mm (50 mil) Attachment: Heavy Duty Fasteners and HD Seam Plates or HD Plus Fasteners and Plates 114" rows, 12" o.c.
Steel 22 ga RD938 230 MPa (33.4 ksi) 2.394 kPa (-50 psf) Project No: 20-06- B0122-3	Vapor Barrier: V-Force BaseGard SA Polyethylene Kraft paper Thermal Barrier (Optional): 6mm – 15.9 mm (1/4" - 5%") thick DensDeck DensDeck DensDeck Prime Securock Attachment: Loose Laid	Insulation: Cover Board Used: Min. 1.5" ISOGARD GL/ISOGARD CG, ISOGARD HD Composite No Cover Board: 50.8 mm (2") thick, ISOGARD GL/ISOGARD CG, ISOGARD HG ISOGARD HD Composite Attachment: 6 HD Fasteners and PVC InvisiWeld Plates per 1219 mm x 2438 mm (4' x8') board	Cover Board (Optional): Min. 6.4 mm (¼") Securock, DensDeck or DensDeck Prime -or- 12.7 mm (½") thick ISOGARD HD -or- Min. 11.1 mm (7/16") APA rated OSB Attachment: 6 PVC InvisiWeld Plates and Heavy Duty Fasteners per 1219 mm x 2438 mm (4' x8') board	Membrane: PVC or PVC KEE 1.3 mm (50 mil) Attachment: Welded to plates used to secure insulation/cover board.
Deck Type & Uplift	Vapor Barrier/ Thermal Barrier	Insulation and Attachment	Cover Board and Attachment	Membrane and Attachment
Steel 22 ga Type B Yield Strength: 275 MPa (40 ksi) Passing Pressure: 135 psf (6.5 kPa) Wind Uplift Resistance (Resistance (Resistance Factor 0.65): 90 psf (4.3 kPa) Document Number: HSP-MARS-5 Test Panel Number: HSP-D2	Vapor Barrier: V-Force (Self-Adhered) BaseGard SA (Self-Adhered) 6-mil Polyethylene Kraft paper Thermal Barrier (Optional): 6 mm – 15.9 mm (¼" - 5%") thick, DensDeck DensDeck Prime Securock Attachment: Loose Laid Adhered Mechanically Attached	Insulation: Top Layer min. 38.1 mm (1.5") thick, 4' x 8' boards ISOGARD GL/ISOGARD CG; ISOGARD HD Composite Attachment with optional Cover Board: Loose Laid Attachment: 12 HD Fasteners and InvisiWeld Plates per 4' x8' board	Cover Board (Optional): Min. 6.35 mm (¼") thick, 4' x4' boards DensDeck Prime Securock OR 1/2" ISOGARD HD OR 7/16" APA Rated OSB Attachment: 12 HD Fasteners and InvisiWeld Plates per 4' x8' board	Membrane: PVC or PVC KEE 1.3 mm (50 mil)

Steel 22 ga Type B Yield Strength: 275 MPa (40 ksi) Passing Pressure: 188 psf (9.0 kPa) Wind Uplift Resistance (Resistance Factor 0.65): 125 psf (5.9 kPa) Document Number: HSP-MARS-6 Test Panel Number: HSP-D3	Vapor Barrier: V-Force (Self-Adhered) BaseGard SA (Self-Adhered) 6-mil Polyethylene Kraft paper <i>Thermal Barrier (Optional):</i> 6 mm – 15.9 mm (¼" - 5⁄a") thick, DensDeck DensDeck Prime Securock Attachment: Loose Laid Adhered Mechanically Attached	Insulation: Top Layer min. 38.1 mm (1.5") thick, 4'x 8' boards ISOGARD GL/ISOGARD CG; ISOGARD HD; ISOGARD HD Composite Attachment with optional Cover Board: Loose Laid Attachment: 20 HD Fasteners and InvisiWeld Plates per 4'x8' board	Cover Board (Optional): Min. 6.35 mm (¼") thick, 4' x4' boards DensDeck Prime Securock OR 1/2" ISOGARD HD OR 7/16" APA Rated OSB Attachment: 20 HD Fasteners and InvisiWeld Plates per 4' x8' board	Membrane: PVC or PVC KEE 1.3 mm (50 mil)
---	--	--	---	--

This guide is meant to highlight Elevate products and specifications provided by Holcim Solutions & Products US, LLC and is subject to change without notice. Holcim takes responsibility for furnishing quality materials which meet published Elevate product specifications or other technical documents, subject to normal roof manufacturing tolerances. Neither Holcim nor its representatives practice architecture. Holcim Solutions & Products US, LLC offers no opinion on and expressly disclaims any responsibility for the soundness of any structure. Holcim accepts no liability for structural failure or resultant damages. Consult a competent structural engineer prior to installation if the structural soundness or structural ability to properly support a planned installation is in question. No Holcim representative is authorized to vary this disclaimer.